

## URANGABAD MUNICIPAL CORPORATION

## FIRE BRIGADE TELPHONE NO-2334000-40FAX No-2331444

Outward No:AMC/FIRE / 12022

Date 24 / 11/2022

To,
Principal,
Agrasen Vidya Mandir, School Building A & B,
Lilasons Campus Gut No. 35,
At. Itkheda Ta. Dist. Aurangabad.

Sub:- Fire NOC Renwal is issued to the Principal, Agracen Vidya Mandir, School Building A & B, Lilasons Campus Gut No. 35, At. Itkheda Ta. Dist. A.bad.

Ref:- 1) Your Letter dated 27/11/2006

2) Final Nos dated 04/09/2021

3) Your Letter dated 18/11/2022

4) GFO Inspection On date 24/11/2022

With Reference to the above subject Fire NOC Renwal is issued to the Principal, Agrasen Vidya Mandir, School Building A & B, Lilasons Campus Gut No. 35, At. Itkheda Ta. Dist. Aurangabad. Plot area 10500.00 mtr.

Sr. No	Name of Building	Height (Meter)	Building No.	No of floors	Area of Plot (Sq. Mtr)	Built up area (Sq. Mtr)	Noc Fees	Total Rs.
1	School Building A	10.50	1	G+2	10500	5801.58	6500	6500
2	School Building B	19.90	1	B+G + 3	10500	3680.04	6500	6500

Following Fire prevention and Fire protection &Fire Fighting measures subject to the is School Building A & B is provided.

- Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
- Underground water tank 50000 lit. & Overhead water tank 10000 lit capacity with the Main fire pump -2280 LPM -01 Nos, Jockey Pump -180 LPM -01 Nos of suitable capacity for building is provided.
- 3. 01 Nos Fire service inlet 2 way incoming is provided.
- O2 Nos. Yard Hydrant points all around the building with fire Hose pipe-02 / Branch-02 Nos is provided.
- 02 Nos Wet Riser Com Down Comer having outlet on all floors with Hose pipe-06 Nos / Branch -06 Nos is provided.
- 6. 14 Nos Hose reel of 100 feet on all outlets is provided.
- 7. Fire Extinguisher of / Co2 / ABC / Fire Buckets of suitable capacity / quantity is provided.
- 8. Automatic Sprinkler system-100 Nos / Manually Operated Electric fire alarm system -02 Nos / Manual Call Point 07 Nos & Hooter -07 Nos is provided.
- 9. Main Staircase 2.00 mtr Width is provided.

- 10 This Certificate shall be treated valid for a period of one year from the date of issue of Fire Noc.
- 11 Fire Noc Renwaled is valide for one year & Noc should be renewed each year.

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashti Fire prevention&Life safety Measures Act 2006 reference to above subject Fire NOC Renwal issued to the Principal, Agrasen Vidya Mandir, School Building A & B, Lilasons Campus Gt No. 35, At. Itkheda Ta. Dist. Aurangabad. Your Fire Noc Next Renewal due date 04/09/2023.

Chief Fire Officer

Fire Brigade Municipal Corporation Aurangabad

Copy to:- A D.T.P AMC, Aurangabad.

Principal
Agrasen Vidya Mandir
Lilasons Campus
Itkheda, Paithan Road,
Aurangabad